

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN DIEGO REGION

ORDER NO. 94-131

WASTE DISCHARGE REQUIREMENTS  
FOR  
SHILOAH SPRINGS BIBLE RETREAT, INC.  
INDIAN HILLS CAMP  
SAN DIEGO COUNTY

The California Regional Water Quality Control Board, San Diego Region (hereinafter Regional Board) finds that:

1. On October 23, 1994 this Regional Board adopted Order No. 78-66, "Waste Discharge Requirements for the Indian Hills Camp Near Jamul." Order No. 78-66 established requirements for the discharge of domestic sewage generated at the facility via septic tank/leach line systems.
2. Order No. 78-66 has been reviewed by Regional Board staff as required by Section 13263 of the California Water Code. This Order updates the Findings, Prohibitions, Discharge Specifications, Provisions, Reporting Requirements, Notifications, and Monitoring and Reporting Program of Order No. 78-66 in order to address current State and Regional Board policies and regulations and the current status of the project.
3. Indian Hills Camp is owned and operated by Shiloah Springs Bible Retreat, Inc.
4. Indian Hills Camp consists of 5 sewerer recreational vehicle spaces, 20 unsewered recreational vehicle or tent campsites, 10 cabins, 2 residences and public restrooms with showers.
5. The sewage disposal systems consists of 2 septic tank/leach line systems. In addition, a recreational vehicle dump station is provided. The dump station is connected to the sewage disposal system. No information has been provided to the Regional Board regarding the design and construction of the sewage disposal system.
6. Septic tank effluent typically contains high concentrations of total dissolved solids, chlorides, phosphates, nitrates, bacteria and viruses. Consequently, subsurface disposal systems must be designed, installed, operated, maintained and monitored so as to continually prevent pollution or contamination of the waters of the State and the creation of a nuisance.
7. Recreational vehicle holding tank wastewater may contain chemical additives that are used to prevent sewage odors. The chemical additives may include formaldehyde, phenols, coal tars, zinc, lime, chlorine, caustic sodas, aluminum sulfates, and other chemicals which may impact water quality. This Order requires the discharger to

implement best management practices to mitigate the potential impacts of the discharge of chemical additives in recreational vehicle wastewater to water quality.

8. In 1976, this Regional Board decided that all campgrounds with a potential for recreational vehicles to discharge holding tank contents into the subsurface disposal system will be required to obtain waste discharge requirements.
9. In June 1980, the Sanitary Engineering Research Laboratory at the University of California, Berkeley published a report for the State Water Resources Control Board entitled "Recreation Vehicle Waste Disposal in Roadside Rest Septic Tank Systems." The report indicated that RV wastes which contain preservatives containing formaldehyde, zinc, and phenols, inhibit degradation of sludge and scum in the septic tank and thereby necessitate large capacity septic tanks and/or more frequent pumping of sludge from the septic tanks.
10. If the discharger complies with the provisions of this Order, the discharge of domestic waste from recreational vehicles should not adversely impact groundwater quality.
11. Water for the camp is supplied by an on-site well.
12. Indian Hills Camp is located in the SE1/4 of Section 6, T17S, R2E, SBB&M, approximately 4 miles east of Jamul. The discharge is in the Dulzura Hydrologic Subunit of the Otay Hydrologic Unit.
13. The "Comprehensive Water Quality Control Plan Report, San Diego Basin (9)" (Basin Plan) was adopted by this Regional Board on March 17, 1975; and subsequently approved by the State Water Resources Control Board (State Board). Subsequent revisions to the Basin Plan have also been adopted by the Regional Board and approved by the State Board.
14. The Basin Plan contains the following prohibitions applicable to the proposed discharge:  
  
"Discharge of treated or untreated sewage or industrial wastes to a natural watercourse upstream of surface storage or diversion facilities used for municipal supply is prohibited."  
  
"Discharge of treated or untreated sewage or industrial wastewater, exclusive of cooling water or other waters which are chemically unchanged, to a watercourse, is prohibited except in cases where the quality of said discharge complies with the receiving body's water quality objectives."  
  
"Discharging of treated or untreated sewage or industrial wastes in such a manner or

volume as to cause sustained surface flow or ponding on lands not owned or under the control of the discharger is prohibited except in cases defined in the previous paragraph and in cases in which the responsibility for all downstream adverse effects is accepted by the discharger."

"The dumping or deposition of oil, garbage, trash or other solid municipal, industrial or agricultural waste directly into inland waters or watercourses or adjacent to the watercourses in any manner which may permit its being washed into the watercourse is prohibited."

15. The Basin Plan establishes the following beneficial uses for the surface waters in the Dulzura Hydrologic Subunit:
  - a. Municipal and domestic supply
  - b. Agricultural supply
  - c. Industrial service supply
  - d. Industrial process supply
  - e. ~~Water contact recreation~~
  - f. Noncontact water recreation
  - g. Warm freshwater recreation
  - h. Wildlife habitat
16. The Basin Plan establishes the following beneficial uses for the groundwater in the Dulzura Hydrologic Subunit:
  - a. Municipal and domestic supply
  - b. Agricultural supply
  - c. Industrial service supply
17. Section 67410.1, et. seq. Chapter 41, Title 22 of the California Health and Safety Code (CH&S) contains requirements prohibiting the sale and use of a material as a chemical toilet additive which contains a nonbiodegradable toxic chemical substance. Criteria for identifying a toxic chemical substance and a nonbiodegradable toxic chemical substance are described in Section 67410.3 and 67410.4 respectfully in the CH&S Code.
18. The Regional Board, in establishing the requirements contained herein, considered factors including, but not limited to, the following:
  - a. Past, present, and probable future beneficial uses of water;
  - b. Environmental characteristics of the hydrologic unit under consideration, including the quality of water available thereto;

- c. Water quality conditions that could reasonably be achieved through the coordinated control of all factors which affect water quality in the area;
  - d. Economic considerations; and
  - e. The need to develop housing within the region.
- 19. The Regional Board has considered all water resource related environmental factors associated with the proposed discharge of waste.
  - 20. The Regional Board in a public meeting heard and considered all comments pertaining to its proposed discharge.
  - 21. This project is an ongoing project and as such is exempt from the provisions of the California Environmental Quality Act, in accordance with Title 14, California Administrative Code, Chapter 3, Article 18, Section 15261.

**IT IS HEREBY ORDERED THAT,** Shiloah Springs Bible Retreat, Inc., as the owner of Indian Hills Camp, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, shall comply with the following:

**A. PROHIBITIONS**

- 1. Neither the treatment nor the discharge of waste shall create a pollution, contamination or nuisance, as defined by Section 13050 of the California Water Code.
- 2. The discharge of waste in a manner other than as described in the findings of this Order is prohibited unless the discharger obtains revised waste discharge requirements that provide for the proposed change.
- 3. Disposal of wastes in a manner that would result in any nuisance condition such as ponding of water or surfacing of sewage is prohibited.
- 4. Odors, vectors, and other nuisances of sewage or sewage sludge origin beyond the limits of the campground are prohibited.

**B. DISCHARGE SPECIFICATIONS**

- 1. The discharge to the subsurface disposal systems shall only consist of domestic sewage.

2. Septage, collected screenings, sludges, other solids removed from liquid wastes, and filter backwash shall be disposed of in a manner approved by the Executive Officer.
3. Discharges to the subsurface disposal system shall be confined underground at all times.
4. The discharge from Indian Hills Camp shall not cause the water quality objectives of the Dulzura Hydrologic Subunit to be exceeded.
5. The discharger shall implement appropriate measures to ensure that no toxic chemical preservatives are discharged by recreational vehicles to the subsurface disposal system. Measures may include:
  - a. Distributing literature to visitors informing them of the potential environmental impacts of using toxic nonbiodegradable chemical preservatives in recreational vehicle holding tanks.
  - b. Installing a dump station with an impermeable storage tank and requiring all recreational vehicles to dump holding tank contents prior to connecting to the subsurface disposal system.
  - c. Eliminating the sale of chemical preservatives which contain harmful chemicals.

The discharger is required as part of the attached monitoring and reporting program, to submit an annual report describing the steps taken to ensure protection of groundwater quality from recreational vehicle holding tank wastes.

6. The discharge shall be limited to domestic sewage from recreational vehicles, residences and public restrooms and showers. If the discharger intends to increase the number of sewered spaces and/or change the treatment or disposal method, a new Report of Waste Discharge must be filed at least 120 days prior to the change.

#### **C. FACILITY DESIGN AND OPERATION SPECIFICATIONS**

1. The discharger shall, at all times, properly operate and maintain all facilities and systems of sewage treatment and disposal (and related appurtenances) which are installed or used by the discharger to achieve compliance with conditions of this Order. Proper operation and maintenance includes:

- a. Routine inspection of the septic tanks to determine sludge and scum depths.
  - b. Routine pumping of septic tank contents when necessary.
  - c. Minimizing the liquid load on the septic system.
  - d. Minimizing the use of septic tank additives.
  - e. Preventing the disposal of household hazardous waste and toxic chemicals and minimizing the disposal of brines, phosphates and other inorganic salts to the septic systems.
2. The discharger shall comply with the attached Monitoring and Reporting Program No. 94-131 and future revisions thereto as specified by the Executive Officer. Monitoring results shall be reported at the intervals specified in Monitoring and Reporting Program No. 94-131.
3. All new sewage disposal systems or replacement systems shall comply with all design and siting criteria specified by the San Diego County Department of Health Services.

#### **D. PROVISIONS**

##### **1. DUTY TO COMPLY**

The discharger must comply with all conditions of this Order. Any noncompliance with this Order constitutes a violation of the California Water Code and is grounds for (a) enforcement action; (b) termination, revocation and reissuance, or modification of this Order; or (c) the denial of a report of waste discharge in application for new or revised waste discharge requirements.

##### **2. ENTRY AND INSPECTION**

The discharger shall allow the Regional Board, or an authorized representative upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the discharger's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this Order;

- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order; and
- d. Sample or monitor at reasonable times, for the purposes of assuring compliance with this Order or as otherwise authorized by the California Water Code, any substances or parameters at any location.

3. CHANGE OF OWNERSHIP

This Order is not transferrable to any person except after notice to the Executive Officer. The Regional Board may require modification or revocation and reissuance of this Order to change the name of the discharger and incorporate such other requirements as may be necessary under the California Water Code. The discharger shall submit notice to the Executive Officer of any proposed transfer of this Order's responsibility and coverage to a new discharger in writing at least 30 days in advance of any proposed transfer. The notice must include a written agreement between the existing and new discharger containing a specific date for the transfer of this Order's responsibility. This agreement shall include an acknowledgement that the existing discharger is liable for violations up to the transfer date and that the new discharger is liable from the transfer date on.

4. PERMIT REVISION

This Order may be modified, revoked and reissued, or terminated for cause including, but not limited to, the following:

- a. Violation of any terms or conditions of this Order.
- b. Obtaining this Order by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- d. The filing of a request by the discharger for the modification, revocation and reissuance, or termination of this Order, or notification of planned changes or anticipated noncompliance does not stay any conditions of this Order.

5. ENDANGERMENT OF HEALTH AND ENVIRONMENT

The discharger shall report any noncompliance which may endanger health or the environment. Any such information shall be provided orally to the Executive Officer within 24 hours from the time the discharger becomes aware of the circumstances. A written submission shall also be provided within five days of the time the discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue, and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance. The Executive Officer, or an authorized representative, may waive the written report on a case-by-case basis if the oral report has been received within 24 hours. Any discharge of treated or untreated wastewater resulting from sewer line breaks or surfacing wastes in the leach fields must be reported to the Executive Officer within 24 hours.

6. TREATMENT FAILURE

In an enforcement action, it shall not be a defense for the discharger that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with this Order. Upon reduction, loss, or failure of the septic tank/leach line system, the discharger shall, to the extent necessary to maintain compliance with this Order, terminate discharges to the failed system, until the system is restored or an alternative method of treatment is provided.

7. INCOMPLETE REPORTS

Where the discharger becomes aware that it failed to submit any relevant facts in a Report of Waste Discharge or submitted incorrect information in a Report of Waste Discharge or in any report to the Regional Board, it shall promptly submit such facts or information.

8. CIVIL MONETARY REMEDIES

The California Water Code provides that any person who intentionally or negligently violates any waste discharge requirements issued, reissued, or amended by this Regional Board is subject to a civil monetary remedy of up to 20 dollars per gallon of waste discharged or, if a cleanup and abatement order is issued, up to 15,000 dollars per day of violation or some combination thereof.



9. CORRECTIVE ACTION

The discharger shall take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this Order, including such accelerated or additional monitoring as may be necessary to determine the nature and impact of the noncompliance and to expedite cleanup.

10. PENALTIES FOR INVESTIGATION, MONITORING OR INSPECTION VIOLATIONS

The California Water Code provides that any person failing or refusing to furnish technical or monitoring program reports, as required under this Order, or falsifying any information provided in the monitoring reports, as required under this Order, is guilty of a misdemeanor.

11. GENERAL REPORTING REQUIREMENT

The discharger shall furnish to the Executive Officer of this Regional Board, within a reasonable time, any information which the Executive Officer may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order. The discharger shall also furnish to the Executive Officer, upon request, copies of records required to be kept by this Order.

12. REPORT DECLARATION

All applications, reports, or information submitted to the Executive Officer shall be signed and certified as follows:

- a. The Report of Waste Discharge shall be signed as follows:
  - (1) For a corporation - by a principal executive officer of at least the level of vice-president.
  - (2) For a partnership or sole proprietorship - by a general partner or the proprietor, respectively.
  - (3) For a municipality, state, federal or other public agency - by either a principal executive officer or ranking elected official.
- b. All other reports required by this Order and other information required by the Executive Officer shall be signed by a person designated in paragraph (a) of this provision, or by a duly authorized representative of that person.

An individual is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph (a) of this provision;
  - (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity; and
  - (3) The written authorization is submitted to the Executive Officer.
- c. Any person signing a document under this Section shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

13. PERMIT REPOSITORY

A copy of this Order shall be maintained at Indian Hills Camp and shall be made available to operating personnel at all times.

14. REGIONAL BOARD ADDRESS

The discharger shall submit reports required under this Order, or other information required by the Executive Officer, to:

Executive Officer  
California Regional Water Quality Control Board  
San Diego Region  
9771 Clairemont Mesa Blvd., Suite B  
San Diego, California 92124-1331


E. NOTIFICATIONS

1. This Order does not convey any property rights of any sort or any exclusive privileges. The requirements prescribed herein do not authorize the commission

of any act causing injury to persons or property, nor protect the discharger from liability under federal, state or local laws, nor create a vested right for the discharger to continue the waste discharge.

2. The provisions of this Order are severable, and if any provision of this Order, or the application of any provision of this Order to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this Order, shall not be affected thereby.
3. These requirements have not been officially reviewed by the United States Environmental Protection Agency and are not issued pursuant to Section 402 of the Clean Water Act.
4. The requirements prescribed by this Order supersede the requirements prescribed in Order No. 78-66. This Order becomes effective on the date of adoption by the Regional Board.

I, Arthur L. Coe, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Diego Region on October 13, 1994.

A handwritten signature in dark ink, appearing to read 'Arthur L. Coe', is written over a horizontal line.

ARTHUR L. COE  
Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN DIEGO REGION

MONITORING AND REPORTING PROGRAM NO. 94-131  
FOR  
SHILOAH SPRINGS BIBLE RETREAT, INC.  
INDIAN HILLS CAMP  
SAN DIEGO COUNTY

**A. MONITORING PROVISIONS**

1. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this Order and, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points shall not be changed without notification to and the approval of the Executive Officer.
2. Monitoring must be conducted according to United States Environmental Protection Agency test procedures approved under Title 40, Code of Federal Regulations (CFR), Part 136, "Guidelines Establishing Test Procedures for Analysis of Pollutants Under the Clean Water Act" as amended, unless other test procedures have been specified in this Order.
3. All analyses shall be performed in a laboratory certified to perform such analyses by the California Department of Health Services or a laboratory approved by the Executive Officer.
4. Monitoring results must be reported on forms contained in Attachment No. 1 unless other forms are approved by the Regional Board Executive Officer.
5. If the discharger monitors any pollutants more frequently than required by this Order, using test procedures approved under 40 CFR, Part 136, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the discharger's monitoring report. The increased frequency of monitoring shall also be reported.
6. The discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order. Records shall be maintained for a minimum of five years from the date of the sample, measurement, report, or application. This period may be extended during the course of any unresolved litigation regarding this discharge or when requested by the Regional Board Executive Officer.

7. Records of monitoring information shall include:
  - a. The date, exact place, and time of sampling or measurements;
  - b. The individual(s) who performed the sampling or measurements;
  - c. The date(s) analyses were performed;
  - d. The individual(s) who performed the analyses;
  - e. The analytical techniques or method used; and
  - f. The results of such analyses.
8. The discharger shall report all instances of noncompliance not reported under Provision D.5 of this Order at the time monitoring reports are submitted. The reports shall contain the information listed in Provision D.5.
9. The monitoring reports shall be signed by an authorized person as required by Provision D.12.
10. A grab sample is an individual sample of at least 100 milliliters collected at a randomly selected time over a period not exceeding 15 minutes.

## **B. ANNUAL REPORT**

The discharger shall submit an annual report that includes completion of the questionnaire in Attachment No. 1 and any other pertinent information that demonstrates that the discharger has achieved compliance with Facility Design and Operation Specification C.1 and Discharge Specification B.5 of this Order.

## **C. EFFLUENT MONITORING**

1. A liquid grab sample of the septic tank which serves either the sewerer recreational vehicle spaces or the dump station shall be collected as close to the outlet pipe as practical. A minimum of one sample shall be taken every five years. The sample shall be analyzed for the following constituents and reported as part of the annual monitoring report:

PARAMETER	UNIT
pH	Unit
Phenols	mg/L

Note: mg/L = milligram per liter

**D. REPORT SCHEDULE**

Monitoring reports shall be submitted to the Executive Officer in accordance with the following schedules:


**MONITORING FREQUENCY**

Annually

**REPORT DUE**

January 30

Ordered by:



ARTHUR L. COE  
Executive Officer  
October 13, 1994

**CERTIFICATION:**

Pursuant to Provision D. 12c of Order No. 94-136, this report must be signed and certified by the discharger or a duly authorized representative of that person as follows:

*"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."*

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Signed under Penalty of Perjury

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

**DIRECTIONS:**

1. As part of the first monitoring report pursuant to this monitoring and reporting program, the discharger shall submit an initial facility map describing the layout of the park and the location of all septic tank(s), leach field(s), leach pit(s) and dump station(s). Clearly identify all features included on the map. For subsequent annual reports the discharger shall submit a facility map only if a change has occurred in the waste disposal systems during the year.
2. Please respond to all questions. If a question does not pertain to your facility, write "Not Applicable" in the space provided.
3. Use page 5 of this report to further demonstrate compliance with waste discharge requirements or to answer any question in greater detail.
4. The discharger shall make copies of this form for annual reporting and save the original to be used as a master copy.

**PARK OWNERSHIP/MANAGEMENT UPDATE**

Please note any changes to the information in the space below:

Name of Facility: Indian Hills Camp

Address: 15763 Lyons Valley Road, CA 91935

Phone Number: (619)466-7716

Owner of Facility: Shiloah Springs Bible Retreat, Inc.

Address: 15763 Lyons Valley Road, CA 91935

Phone Number: (619) 466-7716

Facility Contact Person: \_\_\_\_\_

Phone Number: (619) 478-5677



**PARK DESCRIPTION UPDATE**

1. Number of permanent mobile home spaces \_\_\_\_\_
2. Number of sewer recreational vehicle spaces \_\_\_\_\_
3. Number of unsewered recreational vehicle spaces \_\_\_\_\_
4. Number of tent campsites \_\_\_\_\_
5. Average number of people that visit the park per day during the previous year \_\_\_\_\_
6. Maximum number of people that visited the park per day during the previous year \_\_\_\_\_
7. Number of septic tanks \_\_\_\_\_
8. Size of septic tanks; if known \_\_\_\_\_
9. Number of leach fields (seepage pits) \_\_\_\_\_
10. Length of leach lines; if known \_\_\_\_\_
11. Number of dump stations \_\_\_\_\_
12. Number of dump stations connected to a leach field \_\_\_\_\_
13. Were portable toilets used at the facility this year? Yes \_\_\_\_\_ No \_\_\_\_\_

Describe any changes that have occurred to the park in the last year:

---

---

---

---

---

**SEWAGE TREATMENT AND DISPOSAL FACILITIES MAINTENANCE**

1. Date of last septic tank(s) inspection \_\_\_\_\_
2. Name of person/company who conducted the septic tank inspection \_\_\_\_\_
3. Inspection Results:  

1 <sup>st</sup> Tank Inspected _____	2 <sup>nd</sup> Tank Inspected _____
Depth of scum layer _____ (in)	Depth of scum layer _____ (in)
Depth of liquid layer _____ (in)	Depth of liquid layer _____ (in)
Depth of sludge layer _____ (in)	Depth of sludge layer _____ (in)
4. Date septic tank(s) were last pumped \_\_\_\_\_
5. Name of company who pumped the septic tank(s) \_\_\_\_\_
6. Quantity of septage pumped (gallons) \_\_\_\_\_
7. Submit the lab results of the effluent sampling on Page 4 of this Report. Use as many pages as needed.
8. Location where septage was hauled. \_\_\_\_\_
9. Dump Station(s):  

Number of dump stations	_____
Date(s) dump station(s) were pumped	_____
Quantity of waste pumped	_____
Name of company who pumped dump station(s)	_____
Name of disposal site waste was hauled to	_____
10. Were any odors or surfacing sewage detected at leach field? If yes, what was the cause? and what corrective measures were taken? \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
11. Were any measures taken to prevent non-domestic waste including toxic(s), brines, phosphates or chemical preservatives found in RV holding tanks from being discharged to the subsurface disposal system in the last year? If yes, describe what measures were taken. \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**EFFLUENT ANALYSIS**

Sample date \_\_\_\_\_ Time sample was taken \_\_\_\_\_ a.m./p.m.

Sample location \_\_\_\_\_

Name of individual who performed sampling \_\_\_\_\_

Date sample was analyzed \_\_\_\_\_

Name of individual who performed analysis of sample \_\_\_\_\_

The analytical techniques or methods used to analyze the sample \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SIGNED UNDER PENALTY OF PERJURY \_\_\_\_\_

The Results of Such Analysis:

Parameter	Unit(s)	Sample Results
-----------	---------	----------------

1. pH	Units	_____
-------	-------	-------

2. Phenols	mg/L	_____
------------	------	-------

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Item No. \_\_\_\_\_